GAS SAFETY Information Bulletin



June 2016

G-03-02 Gas [Rev2]Page 1 of 1

Propane/Natural Gas Utility Connections

This bulletin has been jointly developed by Safety Services and the Gas Sub-Council to inform the Canadian Propane Association (CPA) Members, propane suppliers and natural gas utilities of the requirements associated with the verification that a gas permit has been obtained for all new installations where gas is used for fuel purposes.

Propane/Natural Gas Suppliers/Distributors and **Safety Codes Officers** are reminded that a person(s) applying for a gas service for a new installation is required to present a copy of the gas permit to the propane/natural gas supplier. The **Safety Codes Act** under the **Permit Regulation (AR 204/2007)** requires that:

- A gas permit is required to install, alter or make additions to a gas system and includes new or replacement of liquefied petroleum tanks with a capacity in excess of 454 litres, including the service line.
- 2. Propane/natural gas suppliers/distributors shall not supply gas to any installation unless the permit issued in respect of that installation is presented to the supplier by the person applying for the service.
- 3. The issuance of a permit under this regulation to install, alter or make an addition to a gas installation <u>does not</u> obligate a supplier of gas to connect a gas installation to a gas supply system if, in the opinion of the supplier or his agent, the connection would create a hazard to life or property.
- 4. Any permit presented by the applicant for service to a supplier of gas must be retained by the supplier.

A copy of the permit verifies that the gas installation is registered and is subject to a site inspection by a Safety Codes Officer; however, the supplier shall not supply propane to an installation if such action would create a hazard.

The purpose of this information bulletin is to ensure that all propane suppliers/distributors are aware of, and comply with requirements of the *Safety Codes Act*.



Issue of this STANDATA is authorized by the Chief Gas Administrator

