# GAS SAFETY Information Bulletin

# STANDATA

June 2016

G-08-01-B149.1/B149.2 [Rev2] Page 1 of 7 (File number 16090-G01)

#### **Temporary Heat for Construction Sites**

This bulletin has been jointly developed by Safety Services and the Gas Sub-Council to inform the construction industry of the installation requirements for gas-fired construction heaters and torches utilized in Alberta.

Designers, Builders, Rental Companies, Installers, Canadian Propane Association (CPA) Members, Natural Gas/Propane Suppliers and Safety Codes Officers are reminded that construction sites utilizing gas-fired heaters for temporary heating shall comply with the *Safety Codes Act* and Regulations.

The *Safety Codes Act* under the **Permit Regulation** (AR 204/2007) states a permit in the gas discipline is required to install, alter or add to a gas system and includes the following:

- Installation of natural gas and propane construction heaters;
- Gas piping and tubing, hose and fittings from the gas supply;
- All propane containers with a capacity of greater than 454 litres water capacity or when containers are manifolded together, the aggregate capacity of the containers exceed 454 litres water capacity; and
- Propane vaporizers when required.

The permit issuer may issue a permit in the gas discipline to a gasfitter for the installation of gas-fired equipment at a construction site. However, a propane tank set permit may be issued to a person who has satisfactorily completed a course of training acceptable to the Administrator for the installation of propane tanks only.

Note: A supplier of gas shall not connect or supply gas, to any new gas installation until the permit issued in respect of that gas installation is presented to the supplier by the person applying for the service.

The CSA-B149.1 Natural Gas and Propane Installation Code applies to the installation of appliances, equipment, components, and accessories where gas is used for fuel purposes and includes the piping and tubing system.

This Code under Clause 7.18 contains the minimum requirements for construction heaters and torches as follows:

Governmen

Issue of this STANDATA is authorized by the Chief Gas Administrator



[Original Signed] Sidney Manning

Alberta Municipal Affairs – Safety Services, 16<sup>th</sup> Floor, 10155 –102<sup>nd</sup> Street, Edmonton, Alberta, Canada, T5J 4L4 Phone: 1-866-421-6929 Email: <u>safety.services@gov.ab.ca</u> Website: <u>www.municipalaffairs.alberta.ca</u> Safety Codes Council, Suite 1000, 10665 Jasper Avenue, Edmonton, Alberta, Canada, T5J 3S9

#### 7.18.1

A construction heater shall be located to minimize the danger of damage and upset.

#### 7.18.2

A construction heater shall be installed on a solid, level, *noncombustible* base or, where so designed, suspended in accordance with the manufacturer's *certified* installation instructions.

#### 7.18.3

**Combustible** material such as straw, canvas, wood, and debris shall be kept clear of a **construction heater** in accordance with the clearances specified on the **heater's** instruction plate.

#### 7.18.4

When a *construction heater* is operating, an adequate *air supply* shall be provided.

#### 7.18.5

Piping, tubing, *hose*, and *fittings* shall be supported, secured, and protected from damage and strain.

#### 7.18.6

When a *construction heater* is connected to temporary piping, the piping and connections shall be in accordance with the requirements of Clause 6. In addition, a shut-off *valve* shall be provided with a lever or hand wheel when a *branch line* is in service. *Hose* may be used as a *connector* to a *heater* if the shut-off *valve* is installed immediately upstream from the *hose*.

#### 7.18.7

It shall be the responsibility of the lessor of a *construction heater*, at the time of delivery to the lessee, to ensure that

- (a) the *construction heater* is *approved* and in safe operating condition; and
- (b) the lessee is instructed in the safe installation and use of the *construction heater* and *components* in accordance with the requirements of Clause 7.18

# 7.18.8

It shall be the responsibility of the user of a *construction heater* and its *components* to ensure that

- (a) the *construction heater* and its *components* are installed and used in accordance with the requirements of Clause 7.18;
- (b) the maintenance of the *construction heater* and its *components* is performed by a qualified installer;
- (c) the handling and operation of the *construction heater* and its *components* are done by persons who have been instructed in such handling and operation; and
- (d) a malfunctioning or damaged *construction heater* is removed from service.

#### 7.18.9 - A construction heater shall

- (a) only be installed in a *building* under construction, repair, or improvement; and
- (b) not be installed in any inhabited *dwelling unit* or inhabited sections of a *building*.

#### 7.18.10

A torch intended for manual operation shall not be left unattended while in operation.

The CSA-B149.2 Propane Storage and Handling Code, applies to the storage, handling, transfer of propane and includes the installation of containers and equipment.

This Code under Clauses 6 and 7 contains the minimum requirements for cylinder installations and tanks such as the following:

#### 6.4.4

A *cylinder* that is damaged, leaking, or corroded beyond TC limits, or is due for a prescribed re-examination, shall not be filled but shall be removed from service.**6.5.3 Cylinders at construction sites** 

#### 6.5.3.1

A *cylinder* not connected for use shall be stored. A cylinder properly connected for use in an approved manner is not considered in storage.

#### 6.5.3.1.2

A stored *cylinder* shall be located in an area that complies with the requirements of Clause 6.5.3.2, and the storage area shall be outdoors. The following requirements shall apply:

- (a) When the following conditions are met, a storage area utilizing a structure with overhead protection, walls, or both, meets the intent of outdoor storage:
  - (i) The structure is designed to be enclosed by no more than two solid walls on the level the cylinder(s) are stored.
  - (ii) The *cylinders* are located within 25 ft (7.6 m) of an open area of the perimeter opening.
  - (iii) When a wall or the structure is a part of a building, that building must be under construction, repair, improvement, and there shall be no inhabited dwelling units or inhabited section of that building.
  - (iv) There shall be no openings through which gas may travel to a lower elevation, such as open stairway on the floor on which the cylinders are located.
  - (v) There shall be no wall openings through with gases could travel into another structure or building.
- (b) **Cylinders** may be stored in a cabinet in the storage area that meets the requirements of Clause 6.5.1.4.
- (c) A storage area may be on a roof of a structure of building, provided the conditions of Clause 6.5.3.9 are met.

#### 6.5.3.2

Cylinders in storage shall

- (a) be stored in an area that
  - (i) provides protection from tampering;
  - (ii) is free of vehicular or mobile equipment travel, or protected by barriers or equivalent;
  - (iii) has "**NO SMOKING**"\* signs are prominently displayed. These signs shall be in accordance with Clause 7.12.3;
    - \*The equivalent French wording is "D'EFENSE DE FUMER".
  - (iv) meets the requirements of Table 6.3;
- (b) be placed such that the relief valve on any cylinder is not less than 3 ft (.9 m) horizontally from any building opening that is below the level of the relief valve discharge;
- (c) be placed such that the relief valve discharge is not less than 10 ft (3 m) on the horizontal plane from the air intake of any appliance or air-moving equipment;
- (d) be stored in an area that meets Clauses 6.5.1 and 6.5.3.9.

#### 6.5.3.3

Each *cylinder* on a construction site shall be equipped with a collar designed to protect the *cylinder valve* when in use.

#### 6.5.3.4

A cylinder shall not be filled on a construction site unless it is

- (a) installed in accordance with the requirements of Clause 6.7; or
- (b) filled at a location that meets the clearance requirements of Clause 7.17.1.

#### 6.5.3.5

A *cylinder* may be used indoors in the construction, repair, or improvement of a *building* or *structure*, including its fixtures and *equipment*, provided that

- (a) a *pressure regulator* is employed and directly connected to the *appliance* or *cylinder valve*, or located on a manifold that is connected to the *cylinder valve*;
- (b) the total capacity of *cylinders* connected together does not exceed 300 lb (136 kg) of propane, and not more than one such manifold of *cylinders* is located in the same floor area unless separated by a distance of at least 50 ft (15.2 m);
- (c) any *cylinder* with a capacity greater than 1 lb (0.5 kg) of propane is equipped with an *excess-flow valve*. The *excess-flow valve* shall be either integral to the *cylinder valve* or in the connection with the *cylinder valve* outlet. In either case, it shall be installed in such a manner that undue strain beyond the *excess-flow valve* will not cause breakage between the *cylinder* and the *valve*;
- (d) the *cylinder*-regulating *equipment* and manifold are not located where they are subject to damage;
- (e) when repair work is being carried out in a *building* not under construction and occupied, any *cylinder* used in the repair work is under the supervision of the operator at all times;
- (f) each *cylinder* is provided with a protective collar;
- (g) a *cylinder* with a capacity up to and including 100 lb (45 kg) of propane that is *connected for use* to a *construction heater* is secured in an upright position; and
- (h) any construction heater connected to the cylinder is installed and used in accordance with clause 7.18 of CSA B149.1.

#### 6.5.3.6

A *cylinder* in use inside a *building* shall not be located near an exit, stairway, or area intended for the safe evacuation of people.

#### 6.5.3.7

Connection and disconnection of *cylinders* shall be done in a well-ventilated area with no source of *ignition* within 10 ft (3 m) of the point of connection.

# 6.5.3.8

Moving a propane cylinder from one level to another level or the roof of a building may be done using

- (a) a freight, service elevator, or construction hoist; or
- (b) a public passenger elevator or escalator, provided only the person(s) involved with the *cylinder* are in the elevator or escalator.

When moving a propane *cylinder* to or from the roof or one level to another of a building, each *cylinder* valve outlet shall be closed and plugged, and the *valve* proactive cap or collar shall be in place. (see also clause 6.1)

#### 6.5.3.9

#### Cylinders on building rooftops

Cylinders on building rooftops shall comply with the following requirements:

- (a) A propane *cylinder* shall not be on the roof of a building unless the cylinder is to be connected for work undertaken on the roof during the current or the immediate following work shift.
- (b) *Cylinders* not in use shall be stored in accordance with provisions of Clause 6.5.3.2, and the following requirements shall also apply:
  - (i) The weight of the cylinder(s) shall not exceed the net load capacity of the roofing structure as specified by the building owner/management.
  - (ii) The storage area shall be at least 10 ft (3 m) from the building edge or a change in elevation of more than 3 ft (.9 m)
  - (iii) **Cylinders** shall be secured to maintain the cylinders in the proper storage position during inclement weather.
  - (iv) All *cylinders* shall be removed upon completion of the work.
- (c) **Cylinders** properly connected in an approved manner to the appliance they serves shall be adequately secured from inclement weather.
- (d) No more than 1000 lb (450 kg) of propane in total capacity shall be on the roof.

#### 6.7.1

Each *cylinder* shall be set upon a firm, level, weatherproof base, located on consolidated ground at grade level, and shall be equipped with *flexible connectors* to offset any movement affecting the piping or tubing.

#### Propane Tank Systems

#### 7.7.6

A *tank* and its supports that show evidence of damage, deterioration, or incorrect installation shall not be filled.

#### 7.10.1

Except as provided in Clause 5.11 of this Code Clause 5.14.1 of CSA B149.5, every *tank* shall be located outside of a *building*.

# 7.10.2

A *tank* used in a consumer application shall be located with respect to a property line, *building opening*, or an adjacent *tank* in accordance with Table 7.4, except that

- (a) a maximum of four *tanks*, each less than 125 USWG (475 L), that are manifolded together to form a system may be located against a common wall of a *building*. Not more than one such manifold system may be located against a common wall of a *building* unless separated by a distance of 10 ft (3 m);
- (b) when the single largest container in a manifolded system is allowed in Clause 7.10.2(a), then the aggregate capacity in not used when determining separation distance to an important building, group of buildings, or line of adjoining property that can be built upon. The largest single container in the manifolded system shall be used to determine the clearances in Table 7.4

# 7.10.3

A tank used in consumer application shall be located with respect to a property line, building opening, or an adjacent tank in accordance with Table 7.4, except that

- (a) for capacities over 125 USWG (475 L) and up to and including 500 USWG (1900 L), the clearance from building walls may be reduced to 3 ft (1 m) for a single tank, provided that
  - (i) the **building** wall is of concrete or masonry construction;

G-08-01-B149.1/B149.2 [Rev 2] Page 6 of 7

- (ii) there is a minimum of 10 ft (3 m) to the nearest **building opening**; and (iii) the *tank* is used only for vapour service; and
- (b) for capacities over 125 USWG (475 L) and up to and including 5000 USWG (19 000 L), the clearances from *building* walls of other than concrete or masonry construction may be reduced to the clearances specified for concrete or masonry wall construction if protection acceptable to the *authority having jurisdiction* is provided.

When *containers* are installed in locations that do not afford protection from damage from motor vehicles on any street, highway, avenue, alley, or parking lot, they shall be protected by posts or guardrails in compliance with Clause 7.19.4 unless otherwise *approved* by the *authority having jurisdiction*.

Table 7.4   Location of above-ground tanks for consumer applications limited to vapour withdrawal and/or liquid withdrawal to a vaporizer   (See Clauses 7.10.2, 7.10.3 and 9.3.2 and Anney M.)				
Total aggregate water capacity, USWG (L)	Minimum distance, ft (m), between tank and property line; adjacent concrete or masonry building wall with no building openings within the specified clearance; source of ignition*	Minimum distance, ft (m), between tank and building wall of other than concrete or masonry construction	Minimum distance, ft (m), between tank and building opening	Minimum distance, ft (m), between tank and adjacent tank†
Up to and including 125 (475)	None‡	None	3 (0.9)	None
Over 125 (475) up to & including 1000 (3800)	10 (3)	10 (3)	10 (3)	3 (0.9)
Over 1000 (3800) up to & including 2000 (7800)	10 (3)	25 (7.6)	25 (7.6)	3 (0.9)
Over 2000 (7800)up to & including 5000 (19 000)	15 (5)	25 (7.6)	25 (7.6)	3 (0.9)
Over 5000 (19 000) up to & including 10 000 (38 000)	25 (7.5)	25 (7.6)	25 (7.6)	3 (0.9)
Over 10 000 (38 000)	ş	ş	§	§

\* Distances to property lines may be amended by the authority having jurisdiction.

† If tanks of a multiple tank installation are installed on a common base or pier, the clearances may be reduced at the discretion of the authority having jurisdiction.

‡ 10 ft (3 m) from any source of ignition.

§ At the discretion of the authority having jurisdiction.

#### **Direct-fired vaporizers**

#### 9.3.1

Subject to clause 9.3.4, a *direct-fired vaporizer* shall not be permitted in a pumphouse, a *container* filling or storage room, or in any other *building* or room.

#### 9.3.2

A *direct-fired vaporizer* is considered a source of *ignition* and shall be located at a distance in accordance with the requirements of Table 7.4 from any *tank* or from the fill points of any *tank*, and at least 25 ft (7.5 m) from a *building* or property line.

#### 9.3.4

A *direct-fired vaporizer* may be installed in a *building* used exclusively to house it and its related *equipment*, provided that the *building* is constructed in accordance with Clause 7.17.3, and a sign is prominently displayed on the exterior of the building at all entrances with the wording "WARNING: STORAGE OF ANY MATERIALS AND EQUIPMENT IS PROHIBITED"\* (in lettering that is a minimum of 2 in (50 mm) high).

Personnel performing installation, operation, and maintenance work shall be properly trained in such functions. Therefore, it is highly recommended that vendors, construction workers and gasfitters obtain training specifically related to the use and installation of construction heaters.

The purpose of this notice is to ensure that **designers, builders, rental companies, installers** and **gas suppliers** are aware of the provisions for construction heat and that when deviation from the requirements may be necessary, permission shall be obtained from the **authority having jurisdiction** before work proceeds. Such permission will apply only to the specific site and installation for which it is given.

Under the **Safety Codes Act** it is the responsibility of the owner, vendor, contractor, and user to ensure that the installation and operation of construction heaters and torches complies with the *Act* and are in accordance with the regulations.